Demand Flexible Line Voltage and Zonal Thermostat Market Scan and Potential Estimate

Sarah Widder, Scott Reeves, Lucas Judson

8/27/2024



Project Goals

Understand the existing energy efficiency and demand response (DR) capabilities and future potential of connected line voltage and other zonal thermostats

- + Characterize the current market
- + Identify barriers and opportunities for improving energy savings and DR capabilities
- + Develop an "ideal" connected line voltage thermostat that maximizes energy savings and grid flexibility
- + Recommend **next steps** for advancing the technology and the market

A **line voltage** thermostat:

- ✓ Delivers electricity directly to heaters
- ✓ Typically 120V or 240V

A **low voltage** thermostat:

- ✓ Controls central HVAC systems
- ✓ Typically 12V or 24V

An infrared thermostat:

 Communicates with a minisplit controller, which then controls the mini-split itself



Scope of Work



- Manufacturer websites
- Utility DR program websites and reports
- RTF Measures
- Other existing research

Expert Outreach

- Mysa (leading connected LV thermostat manufacturer)
- Daikin Leader in DHP controls development
- Larson Energy Research
- AHR attendees

Learnings

- Current market
- Future developments
- Market and technical barriers and opportunities

Technology Review

| | Line Voltage Thermostat | Low Voltage Thermostat | Infrared Thermostat (Controller) | | |
|---------------------------------|--|---|---|--|--|
| Equipment type | Radiant, convection, or resistance heat | Central HVAC system | Mini-split system | | |
| Control type | Typically one thermostat per room | Typically one thermostat per system or zone (household) | Technically not a "thermostat" | | |
| Communication pathway | Delivers electricity directly to the zonal heating equipment | Delivers electricity to a central HVAC system | Sends control signal to mini-split remote, which controls the equipment | | |







Top LV Thermostat Features

| Feature | Energy Savings | Grid Flexibility |
|---------------------------------|---|---|
| Wi-Fi enabling & App Support | Wi-Fi allows for smart home integration; improves accessibility and participation | Wi-Fi required for DR events |
| Scheduling | Plan reduced usage when away, sleeping, or user not thinking about HVAC | Schedule reduced usage for peak periods; schedule early on to mitigate resident discomfort |
| Reporting | Review usage to identify when to make smarter HVAC choices | Utilities can track effectiveness of DR events |
| Geofencing & Zoning | Reduces energy use when residents are not home & in unoccupied rooms | Future use: DR programs can increase energy reduction; opt in certain rooms for DR programs |
| Multi-equipment optimization | Reduce usage on electrical baseboard when more efficient HVAC also installed | Future use: allows for more flexible DR modes |

Top Manufacturers

Confirmed DR Program-Approved LV & IR

Confirmed DR Program-Approved low V

sinopé mysa ecobee 68 amazon smart thermostat sen Honeywell **Top non-Approved LV & IR Thermostats** Connect Home to Comfo °STELPRO king đ Gnest 360 comfort meross

Market Developments

All manufacturers from the previous slide support the features required for DR program approval.

| Thermostat Type | Findings | | | | | | |
|--------------------------------------|--|--|--|--|--|--|--|
| Connected Line Voltage – DR approved | Mysa investing in multi-equipment (baseboard + DHP) optimization, interested in standardized control approaches but waiting for clear demand | | | | | | |
| Line Voltage – non-DR approved | Did not investigate/contact | | | | | | |
| Low Voltage DR-approved | All interested in standardized control approaches but waiting for clear demand None interested in adding line voltage/baseboard control as a feature | | | | | | |

Summary:

Manufacturers are thinking about standardized control approaches but will not invest without discernable market pressure.




Energy Savings and Demand Response Program Opportunities



What's the Potential?

- Good news same as low voltage (long-term)
 - Lots of controllable load
 - Some studies have shown good response-rates (75%)



Number of units (or buildings) in the Region with electric zonal heat


Barriers:

- Current technology only controls one zone – is this a problem?
- Time and cost are barriers for establishing utility programs – need for standardized control? Is it cost effective?
- Zonal equipment less of a market focus than central HVAC
- Market acceptance of new technology in target markets





Market Adoption





We need more research!

- No robust, publicly available studies available
 - Some limited pilots suggest a range of outcomes
 - NW Power Plan also does not address this technology
- Need to better understand target markets, especially in commercial
 - Understand specific applications, reasonable adoption rates, and barriers to adoption (focus on MF? LI?)
- Need to better understand kW/kWh impacts and cost effectiveness for primary and secondary technologies
 - Need for multi-equipment/zone communication?
 - Standardized communication?





Ideal Thermostat Characteristics



Potential Technology Considerations

- Enhance functionality of top thermostat features
- New features
 - One thermostat controls entire household
 - Open, standardized, and interoperable communication pathway between utility companies and residents

Enhance Top Thermostat Features

| Feature | Future Opportunities | Potential Barriers |
|---------------------------------|---|--|
| Wi-Fi enabling & App Support | Internal mesh network or Wi-Fi hotspot functionality | Cost increase; lack of market momentum |
| Scheduling | Improve early-on functionality and reduce snapback | Low priority for equipment to address snapback |
| Reporting | Consistent data is shared through aggregator or standard communication protocol | Manufacturers have their own preferences for data sharing |
| Geofencing & Zoning | Maximize DR response by further reducing temperatures during peak events | Utilities and manufacturers must invest in improving DR communication functionality; Costly; Requires sensor technology in each room; technically complex; market acceptance in target markets |
| Multi-equipment optimization | More flexible DR response, enhanced energy savings | Costly; technical hurdles such as back-end optimization |

One Thermostat per Household

Why it's important:

- Guarantees entire house is enrolled in DR program
- Reduces discrepancies between thermostats & potential take-back
- May improve customer user experience and reduce costs

Barriers

- Difficult installation and calibration
- Less reliable temperature sensing and adjusting
- DR event opt-out impacts entire household





Standardized Communication Pathway

Why it's important:

- Establishing relationships with individual manufacturers and devices is costly and time intensive
- This would streamline DR programs and increase access for more brands to participate

Barriers

- Manufacturers may not want to relinquish control of the utility-customer relationship
- Requires additional hardware (such as with CTA 2045)
- Market pressure needs to increase



Key Take Aways

- DR-enabled line voltage thermostats exist
- Technology could be improved through multi-equipment control/coordination and open, standardized, interoperable communication
- Can be an important technology for rental units, MF/LI
- More research and evaluation is needed to better understand potential impacts and program implementation best practices
- SCL has been successful in piloting and scaling program in several months, so while more research is helpful, we don't need to wait to get started!



August 27, 2024

Overcoming Winter DR Challenges **RESULTS FROM SEATTLE'S BYOT PILOT**





Presentation Agenda

Intro

- > About TempWise
- > Why Winter DR in the PNW

Winter Challenges:

- > Screening for electric heat
- > Baseboard heating
- > Customer Experience

Load Impacts

Going Forward


> 2nd year improvements





Intro to Seattle City Light TempWise Pilot

INTRO














Why Winter DR in the PNW?

INTRO

- > Winter peaking utility, but seeing summer shortfalls
- Peaks will increase with electrification
- > Climate is changing
 - Record peak of 2,027 MW* on Jan 12, 2024
 - > 2023 Rate Stabilization Account depleted due to extremes



500 0

2500-

2000-


1500

500

August

2026 2030 2035 2041

MW



Scenario

Decembe

2026 2030 2035 2041

YEAR

3 Winter Challenges

1. Screening for Electric Heating

- 2. Baseboard heating
- 3. Customer experience

TempWise Strategies

- Used AMI data, assessor data, and customer self reporting for season assignment
- 2. Added connected line voltage thermostats to OEM line-up
- 3. Tested pre-conditioning, customer notification, and short duration cycling



Challenge 1: Screening for Electric Heat

WINTER CHALLENGES

- No load relief, lower per device kW values
- Customer incentive payments without system benefit
- Extraneous customer email notifications could lead to fatigue, confusion, and opt outs

Strategy

- AMI data screen for winter season implemented
 - Considered assessor data and self reported information

Outcome

• Went from 49% response to 89% average response

Challenge 2: Baseboard Heating

WINTER CHALLENGES

SCL service territory:

- > 45% has electric baseboard
- > 54% is multifamily housing
- > Only 10% of single family has baseboard heating
- > 80% of multifamily has baseboard



Strategy

- Added smart line voltage t-stat to pilot in late Dec 2024
- Included energy efficiency rebate at point-of-sale to boost uptake

Outcome

- Enrolled 197 homes (645 devices) in two weeks.
- Mysa participants consisted of 58% multifamily compared to 20% overall



Challenge 3: Customer Experience

WINTER CHALLENGES

- > People generally don't like to be cold
- Were unsure of customer tolerance for event frequency, duration, temp setback, AM vs PM...



Strategy

- Pre-heating
- Customer notification and awareness of events
 - Day ahead notification
 - Opt out in email
- Cycling events (short duration events)

Outcome

- High levels of event awareness
- Minor impact to comfort
- High satisfaction; slightly lower than summer
- Nearly all reported ease of participation



Event Log / Participant Survey

WINTER CHALLENGES

| Event | Day of Week | Date | Start Time | Duration | Setback | Avg. Outdoor Temp (°F) | Avg. # of Devices | Dispatch Strategy |
|-------|-------------|------------|------------|-----------------------------|------------------------------------|------------------------------|------------------------------|--|
| 1* | Thursday | 12/14/2023 | 6am | 2 hrs | rs 2°F 44 1,314 Combined Platoon – | | Combined Platoon – 2 hr, 2°F | |
| 2* | Friday | 12/22/2023 | 6am | 2 hrs | 2°F | 44 | 1,303 | Combined Platoon – 2 hr, 2°F |
| 3 | Friday | 1/12/2024 | 5pm | 2 hrs | 2°F+2°F 1 hr preconditioning | 16 | 1,977 | Preconditioning |
| 4 | Tuesday | 1/16/2024 | 5pm | 3 hrs | 3°F | 34 | 1,976 | Combined Platoon – 3 hr, 3°F |
| 5* | Thursday | 1/18/2024 | 6pm | 2 hrs | 2°F | 37 | 1,967 | Combined Platoon – 2 hr, 2°F |
| 6* | Friday | 2/9/2024 | 6pm | 2 hrs | 2°F | 42 | 1,962 | Combined Platoon – 2 hr, 2°F |
| 7 | Wednesday | 2/14/2024 | 8am | 2 hrs | 2°F | 45 | 1,959 | Advanced Notification – 30 min vs. night before |
| 8 | Tuesday | 2/27/2024 | 6am | 2.5 hrs | 2°F | 36 | 1,956 | 5 hr Combined Event |
| 8 | Monday | 3/4/2024 | 7am | 3 hrs (1/2 hr intervals) | 2°F | 39 | 1,956 | 3 hr event at 30 min intervals |
| 10 | Tuesday | 3/5/2024 | 7am | 2 hrs | 2°F | 34 | 1,956 | Notification with embedded opt-out option |




Event Awareness

WINTER CHALLENGES

- Majority (94%) aware via several notification options (email, text, phone app, tstat display)
- Majority (80%) indicating pre-notification being helpful


Were you aware of this event? How did you know it was happening?



Participant Comfort

WINTER CHALLENGES

- Majority (72%) found no change in comfort
- > Higher discomfort shift for 1/12 event (morning, low temp)
- Subtle difference for LV (75%) vs. Non-LV Tstats (79%)




Customer Satisfaction

WINTER CHALLENGES

The majority of respondents said that the event was **easy (93%)** and were **satisfied (82%)** with the TempWise program

How easy was this event for your household?





Opt out and Unenrollment results

WINTER CHALLENGES

 Unenrollments: 6 customers unenrolled due to winter events impact


> **Opt-Outs/Overrides**:

 Fewer avg. opt-outs in winter (10%) vs. summer (20%)

> LV vs. Non-LV

- Survey found sig. difference in active overrides between LV homes (6%) and non-LV (18%)
- Opt-out data found slightly lower rates of opt-out for LV *devices* (8%) than non-LV (10%)


Opt-Out Rate and Temperature by Event



LOAD IMPACTS

Morning Events: 0.23 kW Evening Events: 0.26 kW

Overall: 0.25 kW (14%) Plat. A: 0.22 kW Plat. C: 0.26 kW Plat. B: 0.27 kW Plat. D: 0.27 kW






LOAD IMPACTS

| Platoon | Avg Dovices | Avg. kW Reduction per HH | | | | | | | |
|----------------------|--------------|--------------------------|--------|--------|----------|--|--|--|--|
| | Avg. Devices | Overall | Hour 1 | Hour 2 | % Change | | | | |
| Morning Events (n=6) | | | | | | | | | |
| Platoon A | 558 | 0.21 | 0.29 | 0.14 | 52% | | | | |
| Platoon B | 601 | 0.26 | 0.35 | 0.20 | 43% | | | | |
| Platoon C | 55 | 0.20 | 0.31 | 0.10 | 68% | | | | |
| Platoon D (LV Tstat) | 600 | 0.27 | 0.44 | 0.15 | 66% | | | | |
| Total | 1,813 | 0.24 | 0.34 | 0.16 | 53% | | | | |
| Evening Events (n=4) | | | | | | | | | |
| Platoon A | 558 | 0.24 | 0.29 | 0.20 | 31% | | | | |
| Platoon B | 603 | 0.28 | 0.31 | 0.24 | 23% | | | | |
| Platoon C | 67 | 0.26 | 0.31 | 0.21 | 32% | | | | |
| Platoon D (LV Tstat) | 632 | 0.27 | 0.34 | 0.19 | 44% | | | | |
| Total | 1,859 | 0.26 | 0.30 | 0.21 | 30% | | | | |





LOAD IMPACTS

| Event Characteristics Load | | | | | | Reported Load Reductions | Draft Evaluation Load Impacts | | | | | | | | |
|----------------------------|-----------------------|---------------|-----------|-------------|-----------------------------------|--------------------------------|--------------------------------|--|------------------------------------|------------------|--------|--------|--------|-----------------------|---------------------------------------|
| Date | Start Time (PT) | End Time (PT) | Platoon | Pre Heat | Event Max (F) Model Data | No. of Houses | Avg Reduction (kW/House) | Average Event Hour Load Reduction (kW) Per Service Point | Percent of Reference Load | Pre Condition | Hour 1 | Hour 2 | Hour 3 | Post Event Hour | Change From Hour 1 to Hour 2 |
| 1/12/2024 | 5:00 PM | 7:00 PM | Platoon D | No | 32 | 197 | 0.42 | 0.40 | 0.12 | | 0.51 | 0.29 | | -0.31 | 44% |
| 1/16/2024 | 5:00 PM | 8:00 PM | Platoon D | No | 31 | 197 | 0.56 | 0.18 | 0.07 | | 0.47 | 0.04 | 0.01 | -0.36 | 91% |
| 1/18/2024 | 6:00 PM | 8:00 PM | Platoon D | No | 34 | 197 | 0.42 | 0.24 | 0.10 | | 0.38 | 0.11 | | -0.29 | 72% |
| 2/9/2024 | 6:00 PM | 8:00 PM | Platoon D | No | 42 | 197 | 0.21 | 0.28 | 0.15 | | 0.40 | 0.16 | | -0.16 | 61% |
| 2/14/2024 | 8:00 AM | 10:00 AM | Platoon D | No | 38 | 196 | 0.28 | 0.17 | 0.11 | | 0.29 | 0.06 | | -0.22 | 79% |
| 2/27/2024 | 8:30 AM | 11:00 AM | Platoon D | No | 32 | 197 | 0.32 | 0.40 | 0.20 | | 0.47 | 0.34 | 0.40 | -0.07 | 28% |
| 3/4/2024 | 7:30 AM | 10:00 AM | Platoon D | No | 36 | 197 | 0.42 | 0.29 | 0.15 | | 0.30 | 0.28 | | -0.11 | 7% |
| 3/5/2024 | 7:00 AM | 9:00 AM | Platoon D | No | 36 | 197 | 0.21 | 0.20 | 0.09 | | 0.32 | 0.09 | | 0.03 | 73% |

2nd Year Improvements

G O I N G F O R W A R D

Customers report that program is easy to participate in and are largely satisfied, with limited comfort impacts.

Takeaways

- Success with winter heating screen increased response rates from 49% to 89%
- > Line voltage t-stat OEM had positive impact on program
- Clear impact seen in AMI data, but lower kW values per household than expected

Updates

- > Adding HVAC screen for both seasons
- > Expand participation options, continue with LV tstat, explore further screening for load relief
- > Update expected values & refine dispatch strategy
- > Track long-run participation metrics / impact of cumulative participation / fatigue



Thank you!





Emma Johnson Seattle City Light



Scott Reeves Cadeo

Multi Family Line Voltage Load Flex Study

- Studying load shift potential and customer comfort of line voltage thermostats
- Analyze impact when LVTs are applied to entire building
- Survey customers to gain insights into their experience
- Identify device tech/feature upgrades to support performance and open connectivity





Questions?