



# *Integrated Design Lab*

**University of Oregon**

*Mark Fretz and Siobhan Rockcastle*

*January 31, 2023*

*CLASSIFICATION LEVEL: PUBLIC*



# Achieving non-visual health in the workplace using LLCs

An adaptive and dynamic view-based approach to  
evaluating Equivalent Melanopic Lux under daylight and electric lighting scenarios

Siobhan Rockcastle, Alen Mahić


*University of Oregon | Institute for Health in the Built Environment | Energy Studies in Buildings Lab | Baker Lighting Lab*



# Non-Visual Benefits of Light

## 2017 Nobel Prize in Physiology or Medicine

*Jeffrey C. Hall, Michael Rosbash and Michael W. Young*



# Non-Visual Benefits of Light




# Non-Visual Benefits of Light



**Light &  
Dark**

Intensity  
Wavelength  
Duration  
Timing  
History



*Circadian rhythms*


- Sleep and wake
- Hormone secretion
- Body temperature
- Cognitive function

**Non-visual  
responses**

*Direct effects*

- Melatonin suppression
- Pupil constriction
- Subjective alertness
- Performance

# Non-Visual Benefits of Light



<https://www.solemma.com/Alfa.html>

# Non-Visual Benefits of Light

- **Non-visual health**

- Eye-level light exposure that entrains our circadian clock
- Linked to alertness & sleep quality

- **WELL Building Standard**

- Relies on 4-hours of eye-level light exposure for ALL workstations during occupied hours
- Prime exposure is in the morning
- 1-point for 150 EML
- 3-points for 275 EML



# WELL Building Standard – Feature 3, Circadian Lighting Design

WELL v2, Q4 2022

Imperial 中文 Sign in

Light

Overview

P L01 Light Exposure

P L02 Visual Lighting Design

3 Pts L03 Circadian Lighting Design

2 Pts L04 Electric Light Glare Control

4 Pts L05 Daylight Design Strategies

2 Pts L06 Daylight Simulation

1 Pt L07 Visual Balance

3 Pts L08 Electric Light Quality

3 Pts L09 Occupant Lighting Control

For All Spaces Except Dwelling Units

For Dwelling Units

For workstations used during the daytime, electric lighting is used to achieve the following thresholds:

a. The following **light levels** are achieved for at least four hours (beginning by noon at the latest) at a height of 18 in above the work-plane for all workstations in regularly occupied spaces:

| Tier | Threshold                                           |    | Threshold for Projects with Enhanced Daylight                                       | Points |
|------|-----------------------------------------------------|----|-------------------------------------------------------------------------------------|--------|
| 1    | At least 150 EML [136 M-EDI(D65)]                   | OR | The project achieves at least 120 EML [109 M-EDI(D65)] and L05 Part 1 or L06 Part 1 | 1      |
| 2    | At least 275 EML [250 lux M-EDI(D65)] <sup>11</sup> | OR | The project achieves at least 180 EML [163 M-EDI(D65)] and L05 Part 1 or L06 Part 1 | 3      |

b. The **light levels** are achieved on the vertical plane at eye level to simulate the light entering the eye of the occupant.

Verified by Performance Test

**Note:**  
Refer to the Performance Verification Guidebook for information on sensor/testing requirements, required testing duration and compliance calculations.

<https://v2.wellcertified.com/en/wellv2/light/feature/3>

# Custom Simulation Workflow

## Multi-step process that combines:

**Radiance**  
Synthetic Imaging System



- Radiance daylighting & electric lighting simulations
- LARK circadian dosing calculation

## Radiance and LARK:


- Daylight availability and excessiveness
- Electric lighting integrated using IES files
- Shading operation schedules
- Equivalent Melanopic Lux (EML) levels

## Allows us to calculate:


- contribution of daylight and electric light on circadian potential for a series of workstations
- energy required to meet the recommended thresholds using electric lighting
- Compare different control and shading scenarios across the year

# Custom Simulation Workflow

- Increased color resolution via materials and sky definitions:






# Custom Simulation Workflow



# Proof-of-concept




Southwest-facing  
CIE Intermediate sky



Electric lighting needed  
to supplement EML  
levels

# Proof-of-concept

Southwest-facing  
CIE Intermediate sky  
Operated Shading




Electric lighting needed  
to supplement EML  
levels

# Proof-of-concept


West-facing  
TMY3 sky data

Perimeter




Core

Daylight Glare Probability (DGP<0.4)




WELL 2021 EML (150(1pt) 240(2pts))



# Proof-of-concept

West-facing  
TMY3 sky data




Perimeter

Core



with operated shading

Daylight Glare Probability (DGP<0.4)

WELL 2021 EML (150(1pt) 240(2pts))



# Equipment for Validation at NEEA




- **NEEA Offices**

- 88 workstations
- Seating orientations facing primarily east/west with some north/south
- 8 zones of LLC lighting
- Manual shading systems on perimeter

- **Simulation Set-up**

- Simulated annual, climate-based EML at eye-level for all workstations
- Simulated dynamic manual blind use under LM-83 standard
- Simulated 10-steps of dimming for each zone independently
  - EML dosing under daylight conditions is supplemented using LLC lighting system
  - Annual energy demand is a result of LLC needed to supplement eye-level dose



<https://idcl.wsu.edu/llc-curriculum/>

Percent of time of year (9am-1pm) **EML > 150Lux** with daylight only




Percent of time of year (9am-1pm) **EML > 150Lux** with daylight only and operated blinds (LM-83, individual window groups)



Percent of time of year (9am-1pm) **EML > 275Lux** with daylight only




Percent of time of year (9am-1pm) **EML > 275Lux** with daylight only and operated blinds (LM-83, individual window groups)




# Total wattage/dimming needed to meet 150 EML



Blinds always open, without task lighting




**1,817 kWh lighting annually\***  
\*minimum dimming of 20% and maximum dimming of 80%




# Total wattage/dimming needed to meet 150 EML




Blinds always open, with task lighting




**1,466 kWh lighting annually\***  
\*minimum dimming of 20% and maximum dimming of 80%




# Total wattage/dimming needed to meet 150 EML



Interior window shading operated as per IES-LM-83 manual control algorithm, without task lighting




**2,360 kWh lighting annually\***  
\* minimum dimming of 20% and maximum dimming of 80%



# Total wattage/dimming needed to meet 150 EML



Interior window shading operated as per IES-LM-83 manual control algorithm, with task lighting




**1,968 kWh lighting annually\***  
\* minimum dimming of 20% and maximum dimming of 80%


# Total wattage/dimming needed to meet 275 EML



Blinds always open without task lighting




**3,857 kWh lighting annually\***  
\* minimum dimming of 20% and maximum dimming of 80%




# Total wattage/dimming needed to meet 275 EML




Blinds always open with task lighting




**3,619 kWh lighting annually\***  
\* minimum dimming of 20% and maximum dimming of 80%



# Total wattage/dimming needed to meet 275 EML




Interior window shading operated as per IES-LM-83 manual control algorithm, without task lighting



4,223 kWh lighting annually\*


\*does not account for continuous dimming at 20% or demand for private office spaces



# Total wattage/dimming needed to meet 275 EML



Interior window shading operated as per IES-LM-83 manual control algorithm, with task lighting




4,133 kWh lighting annually\*

\*does not account for continuous dimming at 20% or demand for private office spaces


# Monthly Energy Use

From LLC lighting system to meet 150EMLux recommendation as per the WELL Standard




# Monthly Energy Use

From LLC lighting system to meet 275EMLux recommendation as per the WELL Standard




# Annual Energy Use

LLLC to meet 150EMLux WELL Standard threshold:




LLLC to meet 275EMLux WELL Standard threshold:




# Annual Energy Use

LLLC to meet 150EMLux WELL Standard threshold:




LLLC to meet 275EMLux WELL Standard threshold:




# Annual Energy Use

LLLC to meet 150EMLux WELL Standard threshold:




LLLC to meet 275EMLux WELL Standard threshold:



# Percent of workstations that meet 150EMLux





Blinds always open without task lighting



# Percent of workstations that meet 150EMLux





Blinds always open with task lighting




# Percent of workstations that meet 150EMLux

Interior window shading operated as per IES-LM-83 manual control algorithm, without task lighting



# Percent of workstations that meet 150EMLux


Interior window shading operated as per IES-LM-83 manual control algorithm, with task lighting



# Percent of workstations that meet 275EMLux




Blinds always open without task lighting



# Percent of workstations that meet 275EMLux





Blinds always open with task lighting




# Percent of workstations that meet 275EMLux

Interior window shading operated as per IES-LM-83 manual control algorithm, without task lighting



# Percent of workstations that meet 275EMLux

Interior window shading operated as per IES-LM-83 manual control algorithm, with task lighting



# Moving forward

- Based on the WELL standard recommendations, energy use is driven by an algorithm that looks to supplement EML dosing for **ALL** workstations. This means that the **worst offenders are driving up the lighting energy/dimming levels** to satisfy that minority of workstations.
  - **CONTROLS MATTER – future work is needed to explore more optimal approaches**
- Results are exacerbated by the fact that the lighting fixtures are operated in relatively large groups.
  - **BETTER ZONAL CONTROL - Future work could optimize fixture grouping via further simulation of smaller groups (2-3 lighting fixtures/each) to capture potential energy savings**
- Future work needed to challenge the implementation recommendations for WELL to balance health and energy savings more holistically
  - **FIELD STUDIES NEEDED TO SHAPE STANDARDS**

GtCO<sub>2e</sub>

0

20

40

2020

2030

2040

2.8°C

1.8°C

2.0°C

1.5°C

CO<sub>2</sub>

CO<sub>2</sub>

CO

CO<sub>2</sub>

CO<sub>2</sub>

CO<sub>2</sub>




INSTITUTE FOR HEALTH  
IN THE BUILT ENVIRONMENT



# buildings

a big part of the climate  
problem...  
*and the solution*



**buildings 35%**  
1802 MMT CO<sub>2</sub>e

industry 28%


transportation 37%

energie  
sprong



IMAGE CREDIT: ENERGIESPRONG.ORG


- WARM HUMID, DRY TO WARM MARINE
- MIXED HUMID, DRY TO MIXED MARINE
- COOL HUMID, DRY, MARINE
- VERY COLD



SOURCE: [https://earthquake.usgs.gov/scenarios/eventpage/bssc2014cascadia\\_sub0\\_m9p34\\_se/map](https://earthquake.usgs.gov/scenarios/eventpage/bssc2014cascadia_sub0_m9p34_se/map)

## energy + seismic retrofits


areas of climate benefitting from increased façade thermal insulation align with areas of Cascadian subduction zone and present a unique opportunity for combining both efforts.



# Forest to Façade

using mass timber and digital workflows to retrofit inefficient buildings for climate and seismic resilience

*Images - (top) Forest, Eugene Deshko, unsplash.com (mid left, middle) Freres Lumber digital panel processing (mid right) OSU Emmerson Lab digital fabrication (bottom) Freres Lumber MPP Production hall*



# Multifamily Façade Retrofit Project Team

**Mark Fretz (PI)**

Research Assistant Professor  
Institute for Health in the Built Environment  
Department of Architecture

**Kevin Van Den Wymelenberg (Co-PI)**

Professor of Architecture  
Director, ESBL  
Department of Architecture

**Judith Sheine (Co-PI)**

Professor of Architecture  
Director of Design, TallWood  
Department of Architecture

**Jason Stenson (Co-PI)**

Senior Research Assistant I  
ESBL  
Department of Architecture

**Dale Northcutt**

Senior Research Assistant II  
ESBL  
Department of Architecture

**Payton Narancic**

Graduate Student Researcher  
Department of Architecture

**Flynn Casey**

Graduate Student Researcher  
Department of Architecture

**Andre Barbosa (Co-PI)**

Associate Professor  
Civil and Construction Engineering

**Gustavo Fernando Orozco Orozco**

Graduate Student Researcher  
Civil and Construction Engineering

**Phil Mann**

Emmerson Lab Technical Manager  
TallWood

**Mark Gerig**

Emmerson Lab Technician  
TallWood

## Project Support



This work is generously supported by the 2020 Wood Innovations Program grant number 20-DG-11062765-737 from the USDA U.S. Forest Service



# Low-rise multifamily


- 88% of multifamily is 1-3 stories in the PNW
- 1960-1994 before current seismic/energy code
- 64.7% 2x4 construction
- 64% R8-R12 wall Insulation

(Source: NEEA Residential Building Stock Assessment)



# How to Retrofit


# Is the building a candidate?



# Level of performance?

| RETROFIT LEVEL              | STANDARD                                                         | WALLS                                             | CEILING                                        | FLOOR                                                                      | WINDOWS                                                        | DOORS                                                      | AIR INFILTRATION             |
|-----------------------------|------------------------------------------------------------------|---------------------------------------------------|------------------------------------------------|----------------------------------------------------------------------------|----------------------------------------------------------------|------------------------------------------------------------|------------------------------|
| <b>1</b><br>(COMPREHENSIVE) | PHIUS                                                            | R-47                                              | R-89                                           | R-51                                                                       | U-0.16 OR LESS                                                 | R-10                                                       | 0.06 CFM50/FT2 ENVELOPE AREA |
| <b>2</b><br>(MODERATE)      | DOE - ZERO ENERGY READY HOME (ZERH)                              | CZ 4-5: R-20 OR R-13+R-5<br>CZ 6 R20 +5 or R13+10 | CZ 4-6: R-49                                   | CZ 4-6: R-30 SLAB:<br>CZ 4,5 R-10, 2 FT<br>CZ 6 R-10, 4 FT                 | CZ 4-6: U-0.27<br>CZ 4C & 5: U-0.30                            | NR                                                         | LESS THAN 3 ACH 50           |
|                             | ASHRAE 90.2-2018                                                 | CZ 4-5: U-0.060<br>CZ 6: U-0.045                  | CZ 4-6: U-0.026                                | (FLOOR)<br>CZ 4-6: U-0.033 (SLAB)<br>CZ 4-5: R-10, 2FT<br>CZ 6: R-10, 4 FT | CZ 4-6: U-0.32                                                 | CZ 4-6: U-0.32                                             | CZ 4-6: LESS THAN 3 ACH 50   |
|                             | NORTHWEST ENERGY EFFICIENCY ALLIANCE (NEEA) ORSC RECOMMENDATIONS | R-21+R-5                                          | R-60                                           | R-38 (FLOOR)<br>R-10 (SLAB)                                                | U-0.24 OR LESS<br>SHGC 0.27                                    | NR                                                         | LESS THAN 2 ACH 50           |
| <b>3</b><br>(LOW-COST)      | OR CODE (2021 ORSC)                                              | R-15 (EXISTING)<br>R-21 (NEW)                     | (EXISTING)<br>R-21 - R-49 (NEW)<br>R-30 - R-49 | (EXISTING)<br>R-25 - R-30 (NEW)<br>R-30 (SLAB EDGE)<br>R-15                | U-0.26 OR LESS                                                 | U-0.2 WITH <= 2.5 SF GLAZING, U-0.4 WITH >= 2.5 SF GLAZING | LESS THAN 3 ACH 50           |
|                             | CA CODE (2019) TABLE 150.1-B CAL CZ 1,2,14-16                    | U-0.051                                           | R-38                                           | (FLOOR)<br>R-19 (SLAB) CAL CZ 1,2,14 - NR; CZ 16 R-7                       | U-0.30 OR LESS<br>SHGC 0.23 MAX<br>MAX AREA 20%<br>MAX WEST 5% | U-0.20                                                     | NR                           |
| (NO RETROFIT)               | TYPICAL EXISTING CONDITIONS                                      | R-8 - R-12                                        | R-30+                                          | UNINSULATED SLAB                                                           | SINGLE PANE ALUMINUM TYPICAL                                   | NR                                                         | NR                           |

# Seismic vs. Infill





# Digital Workflow




# SCAN EXISTING BUILDING



UNIVERSITY OF  
OREGON

TALLWOOD  
DESIGN INSTITUTE






UNIVERSITY OF  
OREGON

TALLWOOD  
DESIGN INSTITUTE







# Fabricate Panels Offsite



UNIVERSITY OF  
OREGON

TALLWOOD  
DESIGN INSTITUTE









# REMOVE EXISTING EAVE

A photograph of a construction site under an overcast sky. In the foreground, a blue scissor lift is positioned against a building with tan vertical siding. A worker is on the lift, working on the roofline. Two other workers are on the ground; one is holding a long metal rod or pipe. To the left, a hand truck with a wooden board on it sits on a paved surface. The background shows a green field with some animals, a white covered walkway, and a line of trees. A dark wooden fence runs across the middle ground.

# INSTALL 2" MPP TRANSFER JOIST / SPACER



# Rig and Fly Panels



# MOUNT PREASSEMBLED PANELS



# CLOSE PANEL JOINTS



UNIVERSITY OF  
OREGON

TALLWOOD  
DESIGN INSTITUTE





# COMPLETE ROOFING





**Our case study building...**



...revitalized



# DOE ZERH

use the monolithic nature of mass plywood panels with outboard insulation to increase envelope performance of residential housing. panelized prefabrication to reduce costs and increase efficiency.

image credit: Flynn Casey, Christiana Hedlund,  
University of Oregon

TALLWOOD  
DESIGN INSTITUTE

SWINERTON

O UNIVERSITY OF  
OREGON

TIMBERLAB


Oregon State  
University

Freres  
LUMBER CO., INC.

EnergyTrust  
of Oregon

Home  
Work




PROUD  
GROUND  
Dreams Start Here.













# Questions?

(mfretz@uoregon.edu)